

**NON OFFICIAL CERTIFICATE
ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-20-003873**

Only the French PROCÈS-VERBAL is legally acceptable
Seul le PROCÈS-VERBAL français est légalement acceptable.

The French PROCES VERBAL is valid for 5 years starting on December 10, 2020

Applicant	NEOLIFE 11 chemin des Anciennes Vignes 69410 Champagne au Mont d'Or
Sample reference	SPACE - SHADOW
Brief description provided by the applicant	Profiles made up of wood fibers, PVC and specific additives
Mass per unit area determined by the laboratory	8.8 kg/m ²
Thickness measured by the laboratory	6.3 mm
Color	Various
End-use condition	Extruded profil

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-501 (1995)** - Reaction to fire tests Radiation test used for rigid materials, or for materials on rigid substrates (flooring and finishes) of all thicknesses, and for flexible materials thicker than 5 mm

Classification obtained in the official Procès Verbal:

M2

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512 : 1986): Supposedly unlimited

Taking into account the criteria resulting from the tests described in the test report n° RE EFR-20-EPI-003873 from December 10, 2020.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.115-27 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Les Avenières Veyrins-Thuellin, on January 26, 2021

26/01/2021

X

Guillaume LE GOFF

X

Lise RODIER

Project Leader

Signé par : Le Goff Guillaume

Test Supervisor Reaction to Fire

Signé par : Lise RODIER

Nota. - Full reproductions and photocopies of this English abstract of the official PROCES VERBAL of classification or the English version of the official PROCES VERBAL and the attached tests report are authorized.